

BRIERCREST APARTMENTS
ATTN: THOMAS HORNER
4923 SHADYWOOD DRIVE
JEFFERSON, MD 21755

PHONE 301-473-8314
EMAIL HORNERTOM5@AOL.COM

ANNUAL DRINKING WATER QUALITY REPORT

June 17, 2009

Briercrest Apartments

Is my Water Safe?

This report is for 2008 submitted in 2009. Water supply testing is monitored daily for chlorine and pH>2. Water analysis is done on a monthly basis under the state of MD Mde-Water supply program by Sampler Phil Snow with analysis done by Fredericktown Labs. and is submitted to State of Maryland MDE Water Supply Program 2500 Broening Highway Baltimore MD 21224

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as person with cancer undergoing chemotherapy, person who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791)

Where does my water come from?

Water comes from Well. The well is about 235 feet.

On a daily bases the withdraw is approximately 2000 gallons.

Water system is treated daily with Hypochlorite Solution, 8, UN17991, III

Why are the contaminants in my drinking water?

Drinking water, including bottled water*, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline (800-426-4791)

Test Result:

Done on a daily bases:

Chlorine: no validations

Monthly:

Bacteriologic Samples Required 1 per month:

Trihalomethane Samples: Every 3 years

Haloacetic Acid Samples: Every 3 years

Arsenic Samples

Fluoride Samples

Yearly: NO Violations

Copper unit Results 0.075 mg/l /MCL- 1.3

Lead unit results 0.002mg/l /MCL -0.015

Nitrates unit results 1.3mg/l /MCL - 10

Test are monitored as follows:

Daily Samples collected by:

Thomas Horner

Water Superintended

Monthly Samples collected by:

Phil Snow

Mr. Softec, Inc.

Analysis processed monthly by :

Fredericktowne Labs Inc.

to be collected by MDE due 2010

to be collected by MDE due 2010

due 2009

due 2009

***BOTTLE WATER CERTIFICATION NOT REQUIRED**